

Project name

Eversolt Street

As designed

Date: Tue Nov 08 08:27:02 2022

Administrative information

Building Details

Address: ,

Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: DesignBuilder SBEM

Interface to calculation engine version: v6.1.8

BRUKL compliance check version: v5.6.b.0

Certifier details

Name: Neil Ingham

Telephone number:

Address: Holborn Tower, London,

Criterion 1: The calculated CO₂ emission rate for the building must not exceed the target

CO ₂ emission rate from the notional building, kgCO ₂ /m ² .annum	54.7
Target CO ₂ emission rate (TER), kgCO ₂ /m ² .annum	54.7
Building CO ₂ emission rate (BER), kgCO ₂ /m ² .annum	39.7
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

Building fabric

Element	U _a -Limit	U _a -Calc	U _i -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.3	0.3	"Block 1 - CIRCULATION 1_P_8"
Floor	0.25	0.48	0.58	"Block 1 - CIRCULATION 1_S_3"
Roof	0.25	0.18	0.18	"Block 1 - CIRCULATION 1_R_5"
Windows***, roof windows, and rooflights	2.2	5.98	5.98	"Block 2 - BAR & SERVERY_G_11"
Personnel doors	2.2	3	3	"Block 2 - RESTAURANT_D_15"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"
U _a -Limit = Limiting area-weighted average U-values [W/(m ² K)] U _a -Calc = Calculated area-weighted average U-values [W/(m ² K)] U _i -Calc = Calculated maximum individual element U-values [W/(m ² K)]				
* There might be more than one surface where the maximum U-value occurs.				
** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.				
*** Display windows and similar glazing are excluded from the U-value check.				
N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m ³ /(h.m ²) at 50 Pa	10	10

Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	<0.9

1- Bivalent

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	2.55	3.2	-	-	-
Standard value	2.5*	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.					

1- Heat Pump

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	3.2	0.001
Standard value	2*	N/A
* Standard shown is for all types except absorption and gas engine heat pumps.		

Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
Block 1 - WC 1		-	0.9	0.4	-	-	-	-	-	-	-	N/A
Block 1 - OFFICE		-	0.9	0.4	-	-	-	-	-	-	-	N/A
Block 1 - KITCHEN		-	0.9	-	-	-	-	-	-	0.9	-	N/A
Block 1 - STAFF ROOM		-	0.9	-	-	-	-	-	-	-	-	N/A
Block 1 - WC 2		-	0.9	0.4	-	-	-	-	-	-	-	N/A
Block 1 - WC		-	0.9	0.4	-	-	-	-	-	-	-	N/A
Block 2 - BAR & SERVERY		-	-	0.4	-	-	-	-	-	-	-	N/A
Block 2 - WC		-	0.9	0.4	-	-	-	-	-	-	-	N/A
Block 2 - RESTAURANT		-	-	0.4	-	-	-	-	-	-	-	N/A

General lighting and display lighting

Zone name	Luminous efficacy [lm/W]			General lighting [W]
	Luminaire	Lamp	Display lamp	
	Standard value	60	60	22
Block 1 - STORE 1		110	-	16

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
		60	60	22	
Block 1 - CELLAR		110	-	-	34
Block 1 - STORE 2		110	-	-	13
Block 1 - PLANT 1		110	-	-	43
Block 1 - PLANT		110	-	-	75
Block 1 - STORE 3		110	-	-	13
Block 1 - STORE		110	-	-	5
Block 1 - CIRCULATION 1		-	110	-	38
Block 1 - WC 1		-	110	-	186
Block 1 - OFFICE		110	-	-	57
Block 1 - KITCHEN		-	110	-	495
Block 1 - CIRCULATION 2		-	110	-	27
Block 1 - STAFF ROOM		-	110	-	116
Block 1 - CIRCULATION		-	110	-	16
Block 1 - WC 2		-	110	-	21
Block 1 - WC		-	110	-	21
Block 2 - BAR & SERVERY		-	110	-	285
Block 2 - WC		-	110	-	27
Block 2 - RESTAURANT		-	110	110	386
Block 2 - CIRCULATION		-	110	-	31

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Block 1 - CIRCULATION 1	N/A	N/A
Block 1 - WC 1	N/A	N/A
Block 1 - OFFICE	N/A	N/A
Block 1 - KITCHEN	N/A	N/A
Block 1 - CIRCULATION 2	N/A	N/A
Block 1 - STAFF ROOM	N/A	N/A
Block 1 - CIRCULATION	N/A	N/A
Block 1 - WC 2	N/A	N/A
Block 1 - WC	N/A	N/A
Block 2 - BAR & SERVERY	NO (-50.8%)	NO
Block 2 - WC	N/A	N/A
Block 2 - RESTAURANT	YES (+36.7%)	NO
Block 2 - CIRCULATION	N/A	N/A

Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Area [m ²]	558	558
External area [m ²]	1027.7	1027.7
Weather	LON	LON
Infiltration [m ³ /hm ² @ 50Pa]	10	3
Average conductance [W/K]	601.48	302.49
Average U-value [W/m ² K]	0.59	0.29
Alpha value* [%]	6.78	10.94

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area	Building Type
	A1/A2 Retail/Financial and Professional services
100	A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
	B1 Offices and Workshop businesses
	B2 to B7 General Industrial and Special Industrial Groups
	B8 Storage or Distribution
	C1 Hotels
	C2 Residential Institutions: Hospitals and Care Homes
	C2 Residential Institutions: Residential schools
	C2 Residential Institutions: Universities and colleges
	C2A Secure Residential Institutions
	Residential spaces
	D1 Non-residential Institutions: Community/Day Centre
	D1 Non-residential Institutions: Libraries, Museums, and Galleries
	D1 Non-residential Institutions: Education
	D1 Non-residential Institutions: Primary Health Care Building
	D1 Non-residential Institutions: Crown and County Courts
	D2 General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger terminals
	Others: Emergency services
	Others: Miscellaneous 24hr activities
	Others: Car Parks 24 hrs
	Others: Stand alone utility block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	27.26	15.91
Cooling	7.03	20.63
Auxiliary	14.64	16.33
Lighting	22.48	42.74
Hot water	13.48	16.33
Equipment*	117.33	117.33
TOTAL**	84.89	111.93

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	393.76	327.89
Primary energy* [kWh/m ²]	233.82	323.03
Total emissions [kg/m ²]	39.7	54.7

* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] No Heating or Cooling									
Actual	217.1	0.4	0	0	0	0	0	0	0
Notional	118.5	3	0	0	0	0	0	----	----
[ST] Split or multi-split system, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity									
Actual	301.3	144.1	35.2	9.1	18.9	2.37	4.4	2.55	6.2
Notional	129.2	259.2	20.6	26.7	21.1	1.74	2.7	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

Building fabric

Element	U _{i-Typ}	U _{i-Min}	Surface where the minimum value occurs*
Wall	0.23	0.3	"Block 1 - CIRCULATION 1_P_8"
Floor	0.2	0.25	"Block 2 - BAR & SERVERY_F_4"
Roof	0.15	0.18	"Block 1 - CIRCULATION 1_R_5"
Windows, roof windows, and rooflights	1.5	5.98	"Block 2 - BAR & SERVERY_G_11"
Personnel doors	1.5	3	"Block 2 - RESTAURANT_D_15"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"
U _{i-Typ} = Typical individual element U-values [W/(m ² K)]		U _{i-Min} = Minimum individual element U-values [W/(m ² K)]	
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m ³ /(h.m ²) at 50 Pa	5	10