



...sustainable building services solutions

REF: 7127/016/001

5<sup>TH</sup> DECEMBER 2022

Mr Ewan Campbell  
Planning Officer  
London Borough of Camden  
5 Pancras Square  
London  
NIC 4AG

Dear Mr Campbell,

RE PHOTOVOLTAICS FOR PANTHER HOUSE REF: 2022/2633/P

I write to confirm the following photovoltaic allowances for the project, which are as follows;

Panther house (Non-domestic)  
Panel Output - 325W  
Panel Size - 1.6m x 1.0m  
Area - 43.2 m<sup>2</sup>  
kWp - 8.8kW

Gray's Inn Road (Residential)

Panel Output - 325W  
Panel Size - 1.6m x 1m  
Area - 12.8 m<sup>2</sup>  
kWp - 2.6kW

I also enclose a combined roof drawing for both Panther House and Gray's Inn Road.

Yours sincerely

Lee Curtis



ENC: PANTHER HOUSE COMBINED MEP LAYOUT, GRAYS INN ROAD COMBINED MEP LAYOUT

CC:



