

Capacity	Flow Rate	Flow/ATT	Pressure	Req. Attenuation	Actual Attenuation (Using Power Figures)	Actual Attenuation (Using SPressure Figures)
100%	24725.3	8242	42	31	26	29
99%	24424.3	8141	41.12	30.76	26.08	28.96
98%	24123.3	8041	40.24	30.52	26.16	28.92
97%	23822.3	7941	39.36	30.28	26.24	28.88
96%	23521.3	7840	38.48	30.04	26.32	28.84
95%	23220.3	7740	37.6	29.8	26.4	28.8
94%	22919.3	7640	36.72	29.56	26.48	28.76
93%	22618.3	7539	35.84	29.32	26.56	28.72
92%	22317.3	7439	34.96	29.08	26.64	28.68
91%	22016.3	7339	34.08	28.84	26.72	28.64
90%	21715.3	7238	33.2	28.6	26.8	28.6
89%	21414.3	7138	32.32	28.36	26.88	28.56
88%	21113.3	7038	31.44	28.12	26.96	28.52
87%	20812.3	6937	30.56	27.88	27.04	28.48
86%	20511.3	6837	29.68	27.64	27.12	28.44
85%	20210.3	6737	28.8	27.4	27.2	28.4
84%	19909.3	6636	27.92	27.16	27.28	28.36
83%	19608.3	6536	27.04	26.92	27.36	28.32
82%	19307.3	6436	26.16	26.68	27.44	28.28
81%	19006.3	6335	25.28	26.44	27.52	28.24
80%	18705.3	6235	24.4	26.2	27.6	28.2
79%	18404.3	6135	23.52	25.96	27.68	28.16
78%	18103.3	6034	22.64	25.72	27.76	28.12
77%	17802.3	5934	21.76	25.48	27.84	28.08
76%	17501.3	5834	20.88	25.24	27.92	28.04
75%	17200.3	5733	20	25	28	28

UNIT EXPECTED TO OPERATE BETWEEN 90% - 100%. MAXIMUM CAPACITY AVAILABLE TO BE CONFIRMED POST INSTALLATION

UNIT EXPECTED TO OPERATE BETWEEN 90% - 100%. MAXIMUM CAPACITY

AVAILABLE TO BE CONFIRMED POST INSTALLATION

1. THIS CALUCLATION ASSUMES NO PRESSURE LOSS THROUGH CONNECTING PLENUM SECTIONS AS WELL DUCT CONNECTIONS / EXPANSIONS /

THIS DRAWING SHOWS THE DESIGN INTENT ONLY TO ALLOW DESIGN TEAM'S COORDINATION, COSTING AND COMMENT

AT 100%). THIS MUST BE CONFIRMED WITH DAC MANUFACTURER TO CONFIRM NOTE 1 SOUND GENERATION THROUGH LOUVRE TO BE CONFIRMED BY ACOUSTIC ENGINEER

SYSTEM COMPONENTS ARE SUBJECT TO CHANGE PENDING UPDATED INFORMATION

ALL INFORMATION IS INDICATIVE ONLY SUBJECT TO FINAL DESIGN

ALL DIMENSIONS ARE TO BE CONFIRMED ON SITE BEFORE INSTALLATION

2. AN INCREASE TO UNIT STATIC PRESSURE IS EXPECTED OPERATING BELOW 100% CAPACITY (DAC SPECIFICATION ONLY STATES AVAILABLE PRESSURE

PRODUCTS STATED ABOVE ARE NOTIONAL TO PROGRESS DESIGN AND NOT TO BE PROCURED WITHOUT CONFIRMATION FROM BSL AND ACOUSTIC

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SAFETY IN DESIGN HAZARDOUS REGISTER AND OTHER PROJECT H&S DOCUMENTATION

10. IT IS THE CONTRACTORS RESPONSIBILITY TO CHECK ALL DESIGN ELEMENTS HIGHLIGHTED IN THIS DRAWING FOR SAFETY AND CORRECT FUNCTION

Actual

Attenuation

(Using SPressure

Figures)

30.96

30.92

30.88

30.84

30.8

30.76

30.72

30.68

30.64

30.6

30.56

30.52

30.48

30.44

30.4

30.36

30.32

30.28

30.24 30.2

30.16 30.12

30.08

30.04 30



BUILDING SERVICES LIMITED

PROJECT

GREAT RUSSEL STREET HOTEL

CLIENT

CRITERION CAPITAL 16 Babmaes Street St James London SW1Y 6HD

CONSULTANT

Building Services Ltd 4th Floor, Silverstream House, 45 Fitzroy Street, Fitzrovia, London, W1T 6EB +44 (0) 20 7112 5113 contact@buildingsltd.co.uk www.buildingsltd.co.uk

	No.	Description	Date			
	D1	EOD COMMENT	20/04/2022			
_	R1 R2	FOR COMMENT FOR COMMENT	20/01/2022			

Criterion Capital

AIR FLOW SCHEMATIC

Project number	-			
Date	28/01/2022			
Drawn by	-			
Checked by	-			
003				
Scale	N/A			

@100% DAC CAPACITY —		@100% DAC CAPACITY TOTAL EXHAUST			EXHUAST SECTION - ATTENUATORS @1600 x 1200 x 1850mm LENGTH						
0PA - PRESSURE LOSS 80dB - NOISE LEVEL <u>@75% DAC CAPACITY</u> 0PA - PRESSURE LOSS		40PA - PRESSURE LOSS 49dB - NOISE LEVEL <u>@75% DAC CAPACITY</u> 19PA - PRESSURE LOSS	<u>@100% DAC CAPACITY</u> 40PA - PRESSURE LOSS 49dB - NOISE LEVEL	Capacity	Flow Rate	Flow/ATT	<u>Pressure</u>	Req. Attenuation	Actual Attenuation (Using Power Figures)	1	
74dB - NOISE LEVEL		44dB - NOISE LEVEL	<u>@75% DAC CAPACITY</u>	100%	24725.3	8242	40	31	31		
@50% DAC CAPACITY		@50% DAC CAPACITY	19PA - PRESSURE LOSS	99%	24424.3	8141	39.16	30.76	31.2		
0PA - PRESSURE LOSS		8PA - PRESSURE LOSS	44dB - NOISE LEVEL	98%	24123.3	8041	38.32	30.52	31.4		
65dB - NOISE LEVEL	ATT/5/02	44dB - NOISE LEVEL	@50% DAC CAPACITY	97%	23822.3	7941	37.48	30.28	31.6	1.5	
	ATT/E/03		8PA - PRESSURE LOSS	96%	23521.3	7840	36.64	30.04	31.8		
			44dB - NOISE LEVEL	95%	23220.3	7740	35.8	29.8	32	100	
		\ `		94%	22919.3	7640	34.96	29.56	32.2		
				93%	22618.3	7539	34.12	29.32	32.4		
				92%	22317.3	7439	33.28	29.08	32.6	12	
_		\longrightarrow		91%	22016.3	7339	32.44	28.84	32.8		
		\wedge	EXHUAST LOUVRE -	90%	21715.3	7238	31.6	28.6	33	4	
			HIGH CAPACITY / LOW	89%	21414.3	7138	30.76	28.36	33.2	+	
	V		PRESSURE	88%	21113.3	7038	29.92	28.12	33.4	1	
	ATT/E/02		(UP TO 80% FREE AREA	87%	20812.3	6937	29.08	27.88	33.6	+	
			WITH SECURITY MESH -	86%	20511.3	6837	28.24	27.64	33.8		
EXHUAST PLENUM>	EXHUAS	ST PLENUM ———	SELECTION TBC WITH	85%	20210.3	6737	27.4	27.4	34		
			ARCHITECT)	84%	19909.3	6636	26.56	27.16	34.2	4/2	
		\ '	,	83%	19608.3 19307.3	6536	25.72	26.92	34.4 34.6	-	
1				82%		6436	24.88	26.68	34.8	+	
				81% 80%	19006.3 18705.3	6335 6235	24.04	26.44	35	10	
	`			79%	18404.3	6135	22.36	25.96	35.2	12	
	V			78%	18103.3	6034	21.52	25.72	35.4	+	
	ATT/E/01			77%	17802.3	5934	20.68	25.48	35.6	0	
				76%	17501.3	5834	19.84	25.24	35.8	1	
	3 x ATTENUATOR - 1600(W), 1200(H), 1850(L)	•		75%	17200.3	5733	19	25	36	+	
				1374	1,100.3	3,33	**	-		1	

NOTES

DRY AIR COOLER

CONTRACTIONS

ENGINEER