

Project name

Finchey Road - BE GREEN

As designed

Date: Thu Jul 28 14:54:50 2022

Administrative information

Building Details

Address: London, N2

Certifier details

Name: Alexandros Grigoropoulos

Telephone number: 07837047051

Address: Unit A37 Aerodrome Studios, 2-8 Airfield Way,
Christchurch, BH23 3TS

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.15

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.15

BRUKL compliance check version: v6.1.b.0

Foundation area [m²]: 194.2The CO₂ emission and primary energy rates of the building must not exceed the targets

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	2.23
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	2.13
Target primary energy rate (TPER), kWh/m ² annum	24.41
Building primary energy rate (BPER), kWh/m ² annum	23.55
Do the building's emission and primary energy rates exceed the targets?	BER =< TER BPER =< TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _{a-Limit}	U _{a-Calc}	U _{i-Calc}	First surface with maximum value
Walls*	0.26	0.15	0.15	60000000:Surf[3]
Floors	0.18	0.11	0.11	60000000:Surf[6]
Pitched roofs	0.16	-	-	No Pitched roofs in building
Flat roofs	0.18	0.18	0.18	60000000:Surf[5]
Windows** and roof windows	1.6	0.9	0.9	60000000:Surf[0]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors [^]	1.6	-	-	No Personnel doors in building
Vehicle access & similar large doors	1.3	-	-	No Vehicle access doors in building
High usage entrance doors	3	-	-	No High usage entrance doors in building

U_{a-Limit} = Limiting area-weighted average U-values [W/(m²K)]U_{i-Calc} = Calculated maximum individual element U-values [W/(m²K)]U_{a-Calc} = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

[^] For fire doors, limiting U-value is 1.8 W/m²K

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	3

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	>0.95

1- HVAC1. VRF and MVHR (RETAIL/SCHOOL)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	3.5	5.5	0	-	0.8
Standard value	2.5*	5	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					

2- HVAC2. EH and NV (Communal corridors)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	0	-	-
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

1- DHW1 (SCHOOL/DWELLINGS)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	3.5	-
Standard value	2*	N/A
* Standard shown is for all types except absorption and gas engine heat pumps.		

2- DHW2

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	-
Standard value	1	N/A

Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter
NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.	

Zone name	ID of system type	SFP [W/(l/s)]									HR efficiency	
		A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
Classroom		-	-	-	1.1	-	-	-	-	-	-	N/A
Classroom		-	-	-	1.1	-	-	-	-	-	-	N/A
Kitchen		-	-	-	1.1	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
WC	-	-	0.4	-	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
Unit 1	-	-	-	1.1	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
School accomodation	-	-	-	1.1	-	-	-	-	-	-	N/A
School accomodation	-	-	-	1.1	-	-	-	-	-	-	N/A
WC	-	-	0.4	-	-	-	-	-	-	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
Standard value	95	80	0.3	
Classroom	120	-	-	
Plantroom	120	-	-	
Classroom	120	-	-	
LIFT	120	-	-	
Kitchen	120	-	-	
WC	120	-	-	
Store	120	-	-	
Store	120	-	-	
Circulation	120	-	-	
LIFT	120	-	-	
Switchoom	120	-	-	
Circulation	120	-	-	
Unit 1	120	120	1.25	
Circulation	120	-	-	
Store	120	-	-	
Circulation	120	-	-	
Substation	120	-	-	
School accomodation	120	-	-	
School accomodation	120	-	-	
01.04 Corridor	120	-	-	
01 Staircase	120	-	-	
01 Corridor	120	-	-	
04.05 Corridor	120	-	-	
04 Staircase	120	-	-	
WC	120	-	-	
04 Corridor	120	-	-	
Ceiling Void	120	-	-	
Ceiling Void	120	-	-	
Ceiling Void	120	-	-	
01.04 Corridor	120	-	-	

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m ²]
	Standard value	95	80	0.3
01 Staircase		120	-	-
01 Corridor		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
01.04 Corridor		120	-	-
01 Staircase		120	-	-
01 Corridor		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
04 Ceiling Void		120	-	-
04 Ceiling Void		120	-	-
04 Ceiling Void		120	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Classroom	NO (-88.6%)	NO
Classroom	NO (-55.4%)	NO
LIFT	N/A	N/A
Kitchen	N/A	N/A
WC	N/A	N/A
Circulation	N/A	N/A
LIFT	N/A	N/A
Circulation	N/A	N/A
Unit 1	NO (-48.6%)	NO
Circulation	N/A	N/A
Circulation	N/A	N/A
School accomodation	YES (+11.6%)	NO
School accomodation	YES (+9.8%)	NO
WC	N/A	N/A

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	1130.6	1130.6
External area [m ²]	1317.5	1317.5
Weather	LON	LON
Infiltration [m ³ /hm ² @ 50Pa]	3	3
Average conductance [W/K]	252.83	0
Average U-value [W/m ² K]	0.19	0
Alpha value* [%]	25.03	10

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area	Building Type
24	Retail/Financial and Professional Services Restaurants and Cafes/Drinking Establishments/Takeaways
1	Offices and Workshop Businesses General Industrial and Special Industrial Groups Storage or Distribution Hotels Residential Institutions: Hospitals and Care Homes Residential Institutions: Residential Schools Residential Institutions: Universities and Colleges Secure Residential Institutions
42	Residential Spaces Non-residential Institutions: Community/Day Centre Non-residential Institutions: Libraries, Museums, and Galleries
33	Non-residential Institutions: Education Non-residential Institutions: Primary Health Care Building Non-residential Institutions: Crown and County Courts General Assembly and Leisure, Night Clubs, and Theatres Others: Passenger Terminals Others: Emergency Services Others: Miscellaneous 24hr Activities Others: Car Parks 24 hrs Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	0.34	0.74
Cooling	3.79	2.85
Auxiliary	4.14	2.27
Lighting	6.03	7.6
Hot water	1.77	3.52
Equipment*	45.49	45.49
TOTAL**	16.08	16.97

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0.37
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>0.37</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	59.76	54.36
Primary energy [kWh/m ²]	23.56	24.41
Total emissions [kg/m ²]	2.13	2.23

HVAC Systems Performance

System Type	Heat dem MJ/m ²	Cool dem MJ/m ²	Heat con kWh/m ²	Cool con kWh/m ²	Aux con kWh/m ²	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Split or multi-split system, [HS] ASHP, [HFT] Electricity, [CFT] Electricity									
Actual	7.8	127.5	0.6	8.6	9.4	3.43	4.11	3.5	5.5
Notional	12.4	143.6	1.2	8.6	2.1	2.78	4.63	----	----
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity									
Actual	0.6	0	0.2	0	0	1	0	1	0
Notional	1.4	0	0.3	0	0	1.41	0	----	----
[ST] No Heating or Cooling									
Actual	0	0	0	0	0	0	0	0	0
Notional	0	0	0	0	0	0	0	----	----

Key to terms

Heat dem [MJ/m ²]	= Heating energy demand
Cool dem [MJ/m ²]	= Cooling energy demand
Heat con [kWh/m ²]	= Heating energy consumption
Cool con [kWh/m ²]	= Cooling energy consumption
Aux con [kWh/m ²]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type