

## Project name

**Finchey Road - BE LEAN****As designed****Date:** Thu Jul 28 15:05:16 2022

## Administrative information

## Building Details

**Address:** London, N2

## Certifier details

**Name:** Alexandros Grigoropoulos**Telephone number:** 07837047051**Address:** Unit A37 Aerodrome Studios, 2-8 Airfield Way,  
Christchurch, BH23 3TS

## Certification tool

**Calculation engine:** Apache**Calculation engine version:** 7.0.15**Interface to calculation engine:** IES Virtual Environment**Interface to calculation engine version:** 7.0.15**BRUKL compliance check version:** v6.1.b.0**Foundation area [m<sup>2</sup>]:** 194.2The CO<sub>2</sub> emission and primary energy rates of the building must not exceed the targets**The building does not comply with England Building Regulations Part L 2021**

Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> annum	1.91
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> annum	2.87
Target primary energy rate (TPER), kWh/m <sup>2</sup> annum	18.41
Building primary energy rate (BPER), kWh/m <sup>2</sup> annum	30.16
Do the building's emission and primary energy rates exceed the targets?	<b>BER &gt; TER</b> <b>BPER &gt; TPER</b>

## The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U <sub>a-Limit</sub>	U <sub>a-Calc</sub>	U <sub>i-Calc</sub>	First surface with maximum value
Walls*	0.26	0.15	0.15	60000000:Surf[3]
Floors	0.18	0.11	0.11	60000000:Surf[6]
Pitched roofs	0.16	-	-	No Pitched roofs in building
Flat roofs	0.18	0.18	0.18	60000000:Surf[5]
Windows** and roof windows	1.6	0.9	0.9	60000000:Surf[0]
Rooflights***	2.2	-	-	No roof lights in building
Personnel doors^	1.6	-	-	No Personnel doors in building
Vehicle access & similar large doors	1.3	-	-	No Vehicle access doors in building
High usage entrance doors	3	-	-	No High usage entrance doors in building

U<sub>a-Limit</sub> = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>i-Calc</sub> = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]U<sub>a-Calc</sub> = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]

\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\* Display windows and similar glazing are excluded from the U-value check.

\*\*\* Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m<sup>2</sup>K

N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	8	3

## Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	>0.95

### 1- HVAC1. VRF and MVHR (RETAIL/SCHOOL)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	0.81	5.5	0	-	0.8
Standard value	0.93*	5	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					YES
* Standard shown is for gas single boiler systems <=2 MW output and overall for multi-boiler systems. For single boiler systems >2 MW or any individual boiler in a multi-boiler system, limiting efficiency is 0.88.					

### 2- HVAC2. EH and NV (Communal corridors)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	0	-	-
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

### 1- DHW1 (SCHOOL/DWELLINGS)

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	-
Standard value	1	N/A

### 2- DHW2

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	-
Standard value	1	N/A

### Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter
NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.	

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
	Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1		
Classroom		-	-	-	1.1	-	-	-	-	-	-	N/A
Classroom		-	-	-	1.1	-	-	-	-	-	-	N/A
Kitchen		-	-	-	1.1	-	-	-	-	-	-	N/A
WC		-	-	0.4	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I		
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1	Zone	Standard
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
Unit 1	-	-	-	1.1	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
Circulation	-	-	-	1.1	-	-	-	-	-	-	N/A
School accomodation	-	-	-	1.1	-	-	-	-	-	-	N/A
School accomodation	-	-	-	1.1	-	-	-	-	-	-	N/A
WC	-	-	0.4	-	-	-	-	-	-	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
Standard value		95	80	0.3
Classroom		120	-	-
Plantroom		120	-	-
Classroom		120	-	-
LIFT		120	-	-
Kitchen		120	-	-
WC		120	-	-
Store		120	-	-
Store		120	-	-
Circulation		120	-	-
LIFT		120	-	-
Swithcroom		120	-	-
Circulation		120	-	-
Unit 1		120	120	1.25
Circulation		120	-	-
Store		120	-	-
Circulation		120	-	-
Substation		120	-	-
School accomodation		120	-	-
School accomodation		120	-	-
01.04 Corridor		120	-	-
01 Staircase		120	-	-
01 Corridor		120	-	-
04.05 Corridor		120	-	-
04 Staircase		120	-	-
WC		120	-	-
04 Corridor		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
01.04 Corridor		120	-	-
01 Staircase		120	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
	Standard value	95	80	0.3
01 Corridor		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
01.04 Corridor		120	-	-
01 Staircase		120	-	-
01 Corridor		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
Ceiling Void		120	-	-
04 Ceiling Void		120	-	-
04 Ceiling Void		120	-	-
04 Ceiling Void		120	-	-

**The spaces in the building should have appropriate passive control measures to limit solar gains in summer**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
Classroom	NO (-88.6%)	NO
Classroom	NO (-55.4%)	NO
LIFT	N/A	N/A
Kitchen	N/A	N/A
WC	N/A	N/A
Circulation	N/A	N/A
LIFT	N/A	N/A
Circulation	N/A	N/A
Unit 1	NO (-48.6%)	NO
Circulation	N/A	N/A
Circulation	N/A	N/A
School accomodation	YES (+11.6%)	NO
School accomodation	YES (+9.8%)	NO
WC	N/A	N/A

## Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Floor area [m <sup>2</sup> ]	1130.6	1130.6
External area [m <sup>2</sup> ]	1317.5	1317.5
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	3	3
Average conductance [W/K]	252.83	359.49
Average U-value [W/m <sup>2</sup> K]	0.19	0.27
Alpha value* [%]	25.03	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

% Area	Building Type
24	<b>Retail/Financial and Professional Services</b> Restaurants and Cafes/Drinking Establishments/Takeaways
1	<b>Offices and Workshop Businesses</b> General Industrial and Special Industrial Groups Storage or Distribution Hotels Residential Institutions: Hospitals and Care Homes Residential Institutions: Residential Schools Residential Institutions: Universities and Colleges Secure Residential Institutions
42	<b>Residential Spaces</b> Non-residential Institutions: Community/Day Centre Non-residential Institutions: Libraries, Museums, and Galleries
33	<b>Non-residential Institutions: Education</b> Non-residential Institutions: Primary Health Care Building Non-residential Institutions: Crown and County Courts General Assembly and Leisure, Night Clubs, and Theatres Others: Passenger Terminals Others: Emergency Services Others: Miscellaneous 24hr Activities Others: Car Parks 24 hrs Others: Stand Alone Utility Block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	1.26	2.02
Cooling	3.79	2.85
Auxiliary	4.14	1.41
Lighting	6.03	7.6
Hot water	5.63	4.78
Equipment*	45.49	45.49
<b>TOTAL **</b>	<b>20.86</b>	<b>18.66</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	0	5.65
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>5.65</i>

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	59.76	54.36
Primary energy [kWh/m <sup>2</sup> ]	30.16	18.41
Total emissions [kg/m <sup>2</sup> ]	2.87	1.91

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Split or multi-split system, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity										
	Actual	7.8	127.5	2.7	8.6	9.4	0.79	4.11	0.81	5.5
	Notional	12.4	143.6	3.8	8.6	2.1	0.91	4.63	----	----
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity										
	Actual	0.6	0	0.2	0	0	1	0	1	0
	Notional	1.4	0	0.3	0	0	1.41	0	----	----
[ST] No Heating or Cooling										
	Actual	0	0	0	0	0	0	0	0	0
	Notional	0	0	0	0	0	0	0	----	----

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type