

Note: This view is to show approximate location of lighting fittings at site entrances on eastern facade. This view is indicative only

Adelaide Road Vent Shaft
Refer to architectural drawing:
1MC03-SCJ_SDH-AR-DGA-SS02_SL01-440012

1no. B1E luminaire fitted above door at high level


Proposed Luminaire Details

Symbol	Reference	Type	Colour Temperature	Mounting Type	Mounting Height AFFL	Vertical Rotation	Horizontal Rotation
⊙-I	A1	62W LED, DALI, Dimmable	2700K	Building Mounted	6m	30deg above horizontal	30 deg
⊙	A2	31W LED, DALI, Dimmable	2700K	Wall Mounted	2.5m	45deg above horizontal	30 deg
⊙-I	B1	25W LED, DALI, Dimmable	2700K	Building Mounted	3m	Nil	Nil
⊙-I	B2	25W LED, DALI, Dimmable	2700K	Building Mounted	5.5m	Nil	Nil
- -	D1	3.3W LED, DALI, Dimmable	2700K	Handrail	1m	Nil	Nil
- -	D2	3.3W LED, DALI, Dimmable	2700K	Wall Mounted	1m	Nil	Nil
⊙	F1	11W LED, DALI, Dimmable	2700K	Bollard	1.1m	Nil	Nil

Key
Isolines Lighting Contours

Blue line	1.0 lx
Green line	2.0 lx
Yellow line	3.0 lx
Orange line	4.0 lx
Red line	5.0 lx
Purple line	10.0 lx
Dark purple line	20.0 lx

Note:
Suffix "E" identifies luminaires that will be activated in emergency situations. These luminaires to be wired to the Central Battery system. For Example, "A1E" identifies a luminaire of type A1 (As Above) which will be activated in emergency situations.



FOR INFORMATION

P01	EAR-CW_Schedule 17 Submission	AB	SK			HS2 accepts no responsibility for any circumstances which arise from the reproduction of this document after alteration, amendment or abbreviation or if it is issued in part or issued incompletely in any way.
P02	EAR-CW_Schedule 17 LA Submission	MR	CE			© Crown Copyright and database right 2018. All rights reserved. Ordnance Survey Licence number 100049190
P03	EAR-CW_Schedule 17 Final Submission	TB	SK			© Crown Copyright material is reproduced with the permission of Land Registry under delegated authority from the Controller of HMSO. This material was last updated on 2018 and may not be copied, distributed, sold or published without the formal permission of Land Registry. Only an official copy of a title plan or register obtained from the Land Registry may be used for legal or other official purposes.
C01	EAR-CW_Schedule 17 Final Submission	TB	SK	GR		
P04	EAR-MW_Schedule 17 Final Re-Subm. A	TB	SK			
Rev	Description	Drawn	Checked	Con App	HS2 App	Scale with caution as distortion can occur.

Legends/Notes: G1. All dimensions are in millimetres unless noted otherwise. G2. All levels are in metres relative to OD (Ordnance Datum, Newlyn) unless noted otherwise. G3. Chainages are expressed in metres and measured from Euston Station. G4. Global coordinates are indicated by Eastings (E) and Northings (N) to the project snake grid. G5. All angles are in degrees (0°-360°) unless noted otherwise. G6. Dimensions are not to be scaled from the drawing. G7. For the scope of works by the rail systems contractor, as indicatively shown on the drawings, refer to WI 100		1. For Zones and Controls Layout refer to Drg No. 1MC03-SCJ_SDH-EL-DGA-SS02_SL01-440451. 2. For layout drawing showing lux levels when the site is occupied, refer to Drg No. 1MC03-SCJ_SDH-EL-DGA-SS02_SL01-440452. 3. For Lighting and Installation Details refer to Drg No. 1MC03-SCJ_SDH-EL-DDE-SS02_SL01-444451. 4. Drawing to be read in conjunction with Landscape General Arrangement Drg No. 1MC03-SCJ_SDH-LS-DGA-SS02_SL01-441001. 5. This drawing to be used for HS2 Schedule 17 planning applications only. This drawing is not for use for construction.
--	--	---

HS2
Registered in England Registration No. 06791686
Registered office: 2 Snow Hill, Queensway, Birmingham, B4 6QA

OFFICIAL

Creator/Originator
SCS JV - Design House

Zone	Adelaide Road Vent Shaft			Project/Contract	HS2-MWCC SCS Sector S1		
Design Stage	Detail Design			Discipline/Function	Electrical		
Drawing Title	Adelaide Road Vent Shaft Schedule 17 Plans and Specifications External Lighting Lux Levels Site Unoccupied For Information			Drawn	Checked	Approved	
				T Burrige	S King	D.Griffith	
	Date	Scale	Size				
	30/11/22	1:250	A1				
	Drawing No.	Rev.					
	1MC03-SCJ_SDH-EL-DGA-SS02_SL01-440453	P04					