

| Building Name | Unit No. | Floor | Room | Window | Room Use | Illuminance (SDA) | | | Daylight Factor (DF) | | | Sunlight Exposure (SE) | | |
|---------------|----------|--------|----------|---------|----------|-------------------|------------------------------|--------------------------|----------------------|------------------------------|-----------------------|------------------------|-------------------------|-----------------------|
| | | | | | | Target Lux (Lux) | % of Room meeting target (%) | Median Lux of Room (Lux) | Target DF (%) | % of Room meeting target (%) | Median DF of Room (%) | Target (Hrs) | Sunlight Exposure (Hrs) | Orientation (Degrees) |
| Proposed | Flat 1 | Ground | R1 | W1 | LKD | 150 | 59% | 164 | 1.1% | 49% | 1.0% | 1.5 | 4.3 | 233 |
| | | | R2 | W2 | Bedroom | 100 | 100% | 279 | 0.7% | 100% | 1.6% | 1.5 | 4.3 | 233 |
| | | | R3 | W3 | Bedroom | 100 | 100% | 493 | 0.7% | 100% | 3.0% | 1.5 | 3.4 | 233 |
| Flat 2 | Ground | R4 | W4 | LKD | 150 | 79% | 196 | 1.1% | 72% | 1.3% | 1.5 | 1.9 | 233 | |
| | | | R5 | W5 | Bedroom | 100 | 100% | 159 | 0.7% | 100% | 1.1% | 1.5 | 2.4 | 233 |
| Flat 3 | Ground | R6 | W6 W7 | Studio | 150 | 63% | 178 | 1.1% | 57% | 1.1% | 1.5 | 4.3 | 233 | |
| | | | R7 | W8 | LKD | 150 | 81% | 255 | 1.1% | 73% | 1.5% | 1.5 | 2.7 | 233 |
| Flat 4 | Ground | R8 | W9 | Bedroom | 100 | 100% | 525 | 0.7% | 100% | 3.1% | 1.5 | 2.7 | 233 | |
| | | | R9 | W10 | Bedroom | 100 | 96% | 144 | 0.7% | 96% | 0.9% | 1.5 | 2.5 | 233 |
| Flat 5 | Ground | R10 | W11 | LKD | 150 | 57% | 160 | 1.1% | 49% | 1.0% | 1.5 | 2.5 | 233 | |
| | | | R11 | W12 | Bedroom | 100 | 54% | 154 | 0.7% | 52% | 0.9% | 1.5 | 2.5 | 233 |
| Flat 6 | Ground | R12 | W13 | Bedroom | 100 | 100% | 161 | 0.7% | 83% | 0.8% | 1.5 | 1.2 | 233 | |
| | | | R13 | W14 | LKD | 150 | 53% | 159 | 1.1% | 43% | 0.9% | 1.5 | 2.2 | 233 |