

RE: 57 Regent's Park Road - Patron Noise Assessment

Inbox



Dan Flood 17:28

to me, Adrian ▾



Hi Ali,

Please see the predictions and assessment to properties on St Georges Mews below. In short, "none/slight" impact is predicted, which is expected to be subjectively inaudible.

Location	Predicted external noise level (dB)	Resultant Overall Noise Level (dB)	Noise Change (dB)	Impact	Subjective
Existing Average Level (08:00 – 18:00)	46.6	N/A	N/A	N/A	N/A
1 St Georges Mews	39.2	47.3	0.7	None/Slight	Imperceptible
2 St Georges Mews	38.7	47.3	0.7	None/Slight	Imperceptible
3 St Georges Mews	33.7	46.8	0.2	None/Slight	Imperceptible

Kind regards

Daniel Flood

Senior Consultant | AF-Acoustics

m. [REDACTED] | www.af-acoustics.com