

# 40-50 Tottenham Street London



**Planning Compliance Report  
Report 25576.PCR.01**

**Lawrence Coleman  
4k Contracts**

Report 25576.PCR.01					
Revision History					
First Issue Date: 21/12/2022					
A			D		
B			E		
C			F		
Written by:		Checked by:		Approved by:	
Oliver Packman MIOA Senior Acoustic Consultant		Duncan Arkley MIOA Senior Acoustic Consultant		Kyriakos Papanagiotou MIOA Managing Director	
<b>Disclaimer</b> KP Acoustics Ltd. has used reasonable skill and care to complete this technical document, within the terms of its brief and contract with the resources devoted to it by agreement with the client. We disclaim any responsibility to the client and others in respect of any matters outside the stated scope. This report is confidential to the client and we accept no responsibility to third parties to whom this report, or any part thereof, is made known. KP Acoustics Ltd. accepts no responsibility for data provided by other bodies and no legal liability arising from the use by other persons of data or opinions contained in this report. KP Acoustics Ltd. 2022					

## Contents

1.0	INTRODUCTION .....	1
2.0	SITE SURVEYS .....	1
2.1	Site Description .....	1
2.2	Environmental Noise Survey Procedure .....	2
2.3	Equipment.....	4
3.0	RESULTS .....	4
4.0	NOISE ASSESSMENT GUIDANCE .....	5
4.1	BS4142: 2014 ' <i>Methods for rating and assessing industrial and commercial sound</i> ' .....	5
4.2	Local Authority Guidance.....	6
5.0	NOISE IMPACT ASSESSMENT.....	7
5.1	Plant Installation .....	7
5.2	Closest Noise Sensitive Receiver.....	9
5.3	Calculations .....	10
5.4	Anti-Vibration Mounting Strategy .....	10
6.0	CONCLUSION.....	11

### List of Attachments

25576. TH1-2	Environmental Noise Time History
25576.Daytime.LA90 1-2	Statistical analysis for representative daytime $L_{A90}$
25576.Night-time.LA90 1-2	Statistical analysis for representative night-time $L_{A90}$
Appendix A	Glossary of Acoustics Terminology
Appendix B	Acoustic Calculations
Appendix C	Anti-Vibration Mounting Specification Reference Document

## INTRODUCTION

### 1.0

KP Acoustics Ltd has been commissioned by 4k Contracts, 7 Pollards Way, Henlow, Bedfordshire, SG16 6NF to undertake a noise impact assessment of a plant unit installation serving the building at 40-50 Tottenham Street, W1T 4RN, London.

A 72-hour environmental noise survey has been undertaken on site along with manual measurements of installed plant in order to prepare a noise impact assessment in accordance with BS4142:2014 'Method for rating and assessing industrial and commercial sound' as part of the condition 16 planning requirements (notated below) of the London Borough of Camden.

*'Prior to use of any plant full details of all plant, including details of sound attenuation and an acoustic report setting out how the equipment would meet the Council's noise standards shall be submitted to and approved in writing by the local planning authority. The development shall not be carried out otherwise than in accordance with any approval given and shall thereafter be maintained in effective order to the reasonable satisfaction of the local planning authority'*

This report presents the methodology and results from the environmental survey, followed by calculations in accordance with BS4142 to provide an indication as to the likelihood of the noise emissions from the proposed plant unit installation having an adverse impact on the closest noise sensitive receiver. Mitigation measures will be outlined as appropriate.




Figure 2.1 Site Location Plan (Image Source: Google Maps)

## 2.0 SITE SURVEYS

### 2.1 Site Description





As shown in Figure 2.1, the site is bounded by the Middlesex House, an office to the north, a hospital over Cleveland Street to the west, Tottenham Street to the south, and residential areas and office spaces to the east.

Initial inspection of the site revealed that the background noise profile at the monitoring location was typical of an urban cityscape environment, with the dominant source being road traffic noise from the surrounding roads, construction works from various surrounding sites and plant serving other buildings. It should be noted that plant on the rooftop of 40-50 Tottenham Street was switched off for the duration of the 72-hour survey.

### 2.2 Environmental Noise Survey Procedure


Continuous automated monitoring was undertaken for the duration of the noise survey between 12.36 on 16/12/2022 and 10.14 on 16/12/2022.

The environmental noise measurement positions, proposed plant installation locations, and the closest noise sensitive receiver relative to the plant installations are described within Table 2.1 and shown within Figures 2.2 and 2.3.

Icon	Descriptor	Location Description
	Noise Measurement Position 1	The microphone was installed on a tripod on the southeast corner of the roof of the building, as shown in Figure 2.2.
	Noise Measurement Position 2	The microphone was installed on a tripod on the southwest corner roof of the building, as shown in in Figure 2.2.
	Closest Noise Sensitive Receivers	Residential properties to the east, 38 Tottenham Street overlooking Tottenham Mews. Residential properties to the west, 25 Cleveland Street.
	Plant Installation Locations	Plant installations are outlined in Section 5

**Table 2.1 Measurement position and description**





Architectural floor plan of the 10th floor of the 1000 West 10th Street building. The plan shows various rooms, including a large central hall, several smaller rooms, and a large outdoor area on the right. Key features include a 'NEW PLANT SCREENS' area, a 'POTENTIAL ZONE FOR POTENTIAL PLANT SCREENS', and a 'POTENTIAL ZONE FOR POTENTIAL PLANT SCREENS'. The plan is overlaid with a grid system (A-L, 0-19) and includes various annotations and dimensions.

**Figure 2.3 24-Hour site measurement position (Image Source: 4k Contracts)**

While on site, manual noise measurements were also taken of rooftop plant running at design duty at selected locations across the roof of the plant. Details of the results of these measurements are given in Section 5.1

Weather conditions were generally dry with light winds and therefore suitable for the measurement of environmental noise. The measurement procedure complied with ISO 1996-

2:2017 Acoustics 'Description, measurement and assessment of environmental noise - Part 2: Determination of environmental noise levels'.

### 2.3 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed. The equipment used is described within Table 2.2.

Measurement instrumentation		Serial no.	Date	Cert no.
Noise Kit 28	NTI Audio XL2 Class 1 Sound Level Meter	A2A-21140-E0	04/08/2022	UK-22-076
	Free-field microphone NTI Acoustics MC230A	A23592		
	Preamp NTI Acoustics MA220	10981		
	NTI Audio External Weatherproof Shroud	-	-	-
Noise Kit 29	NTI Audio XL2 Class 1 Sound Level Meter	A2A-21120-E0	21/07/2022	UK-22-065
	Free-field microphone NTI Acoustics MC230A	A23073		
	Preamp NTI Acoustics MA220	11033		
	NTI Audio External Weatherproof Shroud	-	-	-
B&K Type 4231 Class 1 Calibrator		2147411	24/05/2022	UCRT22/1581

**Table 2.2 Measurement instrumentation**

### 3.0 RESULTS

The  $L_{Aeq: 5min}$ ,  $L_{Amax: 5min}$ ,  $L_{A10: 5min}$  and  $L_{A90: 5min}$  acoustic parameters were measured throughout the duration of the survey. Measured levels are shown as a time history in Figure 25576.TH1.

Representative background noise levels are shown in Table 3.1 for daytime and night-time.

It should be noted that the representative background noise level has been derived from the most commonly occurring  $L_{A90,5 min}$  levels measured during the environmental noise survey undertaken on site, as shown in 25576.Daytime.LA90 and 25576.Night-time.LA90 attached.

Time Period	Representative background noise level $L_{A90}$ dB(A)	
	P1	P2
Daytime (07:00-23:00)	53	54
Night-time (23:00-07:00)	52	52

**Table 3.1 Representative background noise levels**

## 4.0 NOISE ASSESSMENT GUIDANCE

### 4.1 BS4142: 2014 'Methods for rating and assessing industrial and commercial sound'

British Standard BS4142:2014 'Methods for rating and assessing industrial and commercial sound' describes a method for rating and assessing sound of an industrial and/or commercial nature, which includes:

- Sound from industrial and manufacturing processes
- Sound from fixed installations which comprise mechanical and electrical plant and equipment
- Sound from the loading and unloading of goods and materials at industrial and/or commercial premises, and
- Sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from premises or processes.

This Standard compares the Rating Level due to the noise source/s under assessment for a one-hour period during the daytime (07:00 – 23:00 hours) and a fifteen-minute period during the night-time (23:00 – 07:00 hours) with the existing background noise level in terms of an  $L_{A90}$  when the noise source is not operating.

It should be noted that the Rating Level is the Specific Sound Level in question ( $L_{Aeq, T_r}$ ), including any relevant acoustic feature corrections, as follows:

- **Tonality** – 'For sound ranging from not tonal to prominently tonal the Joint Nordic Method gives a correction of between 0dB and +6dB for tonality. Subjectively, this can be converted to a penalty of 2dB for a tone which is just perceptible at the noise receptor, 4dB where it is clearly perceptible, and 6dB where it is highly perceptible'
- **Impulsivity** – 'A correction of up to +9dB can be applied for sound that is highly impulsive, considering both the rapidity of the change in sound level and the overall change in sound level. Subjectively, this can be converted to a penalty of 3dB for



*impulsivity which is just perceptible at the noise receptor, 6dB where it is clearly perceptible, and 9dB where it is highly perceptible'*

- **Intermittency** – *'If the intermittency is readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied'*
- **Other sound characteristics** – *'Where the specific sound features characteristics that are neither tonal nor impulsive, though otherwise are readily distinctive against the residual acoustic environment, a penalty of 3dB can be applied'*

Once the Rating Level has been obtained, the representative background sound level is subtracted from the Rating Level to obtain an initial estimate of the impact, as follows:

- Typically, the greater this difference, the greater the magnitude of the impact
- A difference of around +10 dB or more is likely to be an indication of a significant adverse impact, depending on the context
- A difference of around +5 dB could be an indication of an adverse impact, depending on the context
- The lower the rating level is relative to the measured background sound level, the less likely it is that there will be an adverse impact or significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound having a low impact, depending on the context

*NOTE: Adverse impacts may include but not be limited to annoyance and sleep disturbance. Not all adverse impacts will lead to complaints and not every complaint is proof of an adverse impact.*

The initial estimate of the impact may then be modified by taking consideration of the context in which the sound occurs.

#### **4.2 Local Authority Guidance**

The guidance provided by The London Borough of Camden for noise emissions of new plant in this instance is as follows:

*The noise criteria, as per the Local Plan 2017 of London Borough of Camden, British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' should be considered as the main reference document for the assessment. The resultant 'Rating Level' would be considered as follows:*

Period	Assessment Location	Rating Level Acceptability Range		
		Green: noise is considered to be at an acceptable level	Amber: noise is observed to have an adverse effect level, but which may be considered acceptable when assessed in the context of other merits of the development	Red: noise is observed to have a significant adverse effect.
Daytime (7:00-23:00)	Garden used for main amenity (free field) and Outside living or dining or Bedroom window (façade)	10dB below background	9 dB below and 5dB above background	5dB above background
Night-time (23:00-7:00)	Outside bedroom window (façade)	10dB below background and no events exceeding 57dB $L_{Amax}$	9db below and 5dB above background or noise events between 57dB and 88dB $L_{Amax}$	5dB above background and/or events exceeding 88dB $L_{Amax}$

**Table 4.1 Camden noise criteria for plant and machinery**

## 5.0 NOISE IMPACT ASSESSMENT

### 5.1 Plant Installation

It is understood that the plant installation is comprised of the following units:

- 6 No. REYQ10T VRV IV Daikin Air Conditioning Unit (REYQ-T)
- 3 No. REYQ12T VRV IV Daikin Air Conditioning Unit (REYQ-T)
- 1 No. REYQ14T VRV IV Daikin Air Conditioning Unit (REYQ-T)
- 4 No. REYQ16T VRV IV Daikin Air Conditioning Unit (REYQ-T)
- 1 No. REYQ20T VRV IV Daikin Air Conditioning Unit (REYQ-T)
- 3 No. REYQ8T VRV IV Daikin Air Conditioning Unit (REYQ-T)
- 2 No. RYMQ12T VRV IV Continuous Heating Daikin Air Conditioning Unit (RYYQ-T)
- 4 No. RYMQ16T VRV IV Continuous Heating Daikin Air Conditioning Unit (RYYQ-T)
- 2 No. RYYQ18T VRV IV Continuous Heating Daikin Air Conditioning Unit (RYYQ-T)
- 4 No. RXYSCQ4TVI Daikin Extraction Fan

- 1 No. Nuaire AM Airmover AM45ES Toilet Extract Fan
- 2 No. Easy Air Handling Unit Supply
- 2 No. Easy Air Handling Unit Extract

The installation location for the plant is on the roof, as shown in Figure 5.1 below.

The noise emission levels as measured on site with all plant running at design duty are shown in Table 5.1. along with corresponding measurements positions in Figure 5.1.

Measurement Location	Descriptor	Octave Frequency Band (Hz)								Overall (dBA)
		63	125	250	500	1k	2k	4k	8k	
1- Edge of plant compound 2.5m from centre of condensers	SPL @2.5m (dBA)	68	67	65	62	58	52	47	40	59
2 - Centre of condenser units approximately 1m from closest unit	SPL @1m (dBA)	76	73	71	70	66	59	55	47	67
3 - By AHU Supply casing measuring case breakout	SPL @1m (dBA)	69	67	60	58	53	52	50	38	57
4 – By edge of roof 7m from centre of condenser compound	SPL @7m (dBA)	64	63	59	59	53	46	42	29	55
5 – Condensers serving AHUs at 1m	SPL @1m (dBA)	78	72	72	69	64	57	53	43	66
6 – Supply AHU 1m from termination point (noise dominated by condensers)	SPL @1m (dBA)	68	66	61	59	52	44	41	31	54
7 - Exhaust AHU 1m from termination point (noise dominated by condensers)	SPL @1m (dBA)	72	63	59	62	59	54	49	42	60
8 - Exhaust AHU 1m from termination point (noise dominated by condensers)	SPL @1m (dBA)	71	62	59	60	56	52	46	36	58

**Table 5.1 Plant Units Noise Emission Levels Measured On-site**




Figure 5.1 Manual measurement locations (Image Source: 4k Contracts)

During the site visit, the toilet extract fan was not active and therefore the noise level due to this item has been predicted from the manufacturer data given in Table 5.2 below

Unit	Descriptor	Octave Frequency Band (Hz)								Overall (dBA)
		63	125	250	500	1k	2k	4k	8k	
Toilet Extract Fan	Duct Termination SWL (dBA)	85	84	81	78	71	69	66	61	79
	Case breakout SWL (dBA)	77	78	70	54	40	38	44	35	65
Toilet Extract Attenuator	Insertion Loss (dB)	5	7	15	30	28	20	15	11	-

Table 5.2 Plant Units Noise Emission Levels provided by manufacturer

## 5.2 Closest Noise Sensitive Receiver

The closest noise sensitive receiver to the installation location has been identified as being a residential window at 38 Tottenham Street overlooking Tottenham Mews on the east facade, located approximately 23 metres from the centre of the plant installation, as shown in Figure 2.2.

It should be noted the plant units would be out of line of site of the receiving window due to screening from the building envelope.

The most exposed noise sensitive receiver to the installation location has been identified as being a residential window at 25 Cleveland Street, located approximately 50 metres from the centre of the plant installation, as shown in Figure 2.2. This receiver is in direct line of sight to the plant installation.

### 5.3 Calculations

The 'Rating Level' of each plant unit installation has been calculated at 1m from the closest receiver using the noise levels shown in Table 5.1, and corrected due to different acoustic propagation features such as distance, reflective surfaces, screening elements, etc.

No acoustic feature corrections as per BS4142 have been applied as the source is not considered to have intermittent, impulsive or tonal characteristics.

Detailed calculations for each plant unit installation are shown in Appendix B

Receiver	Criterion	Noise Level at 1m From the Closest Noise Sensitive Window
38 Tottenham Street	42dB(A)	39dB(A)
25 Cleveland Street		42dB(A)

**Table 5.2 Predicted noise level and criterion at nearest noise sensitive location**

As shown in Appendix B and Table 5.2, transmission of noise to the nearest sensitive windows due to the effects of the plant unit installation satisfies the emissions criterion of The London Borough of Camden.

### 5.4 Anti-Vibration Mounting Strategy

In the case of all plant units, appropriate anti-vibration mounts should have been installed in order to ensure that vibrations do not give rise to structure-borne noise. Appendix C outlines detailed advice in order to ensure that the system installer selects the appropriate anti-vibration mount for the installation.

It is the supplier's responsibility to ensure that all mountings offered are suitable for the loads, operating and environmental conditions which will prevail.



## 6.0 CONCLUSION

An environmental noise survey has been undertaken at 40-50 Tottenham Street, W1T 4RN, London, by KP Acoustics Ltd between 12.36 on 16/12/2022 and 10.14 on 16/12/2022. The results of the survey have enabled a representative background noise level to be set.

Manufacturer's noise data of proposed plant units has been used to obtain Specific and Rated Noise Level at the nearest noise sensitive receiver in accordance with British Standard BS4142:2014 for compliance with The London Borough of Camden requirements.

The rating level was compared with the representative background noise level to assess the likelihood of impact considering the environmental noise context of the area as per the requirements of BS4142:2014.

It has been concluded that noise emissions from the proposed plant units would not have an adverse impact on the nearest residential receivers.

40-50 Tottenham Street - Position 1  
Environmental Time History  
16/12/2022 to 19/12/2022




Figure 25576.TH1

40-50 Tottenham Street - Position 1  
Representative Daytime Background Noise Level  
16/12/2022 to 19/12/2022




Figure 25576.Daytime L90.TH1

40-50 Tottenham Street - Position 1  
Representative Night-time Background Noise Level  
16/12/2022 to 19/12/2022




Figure 25576.Night-time L90.TH1

40-50 Tottenham Street - Position 2  
Environmental Time History  
16/12/2022 to 19/12/2022




Figure 25576.TH2



40-50 Tottenham Street - Position 2  
Representative Daytime Background Noise Level  
16/12/2022 to 19/12/2022




Figure 25576.Daytime L90.TH2

40-50 Tottenham Street - Position 2  
Representative Night-time Background Noise Level  
16/12/2022 to 19/12/2022




Figure 25576.Night-time L90.TH2

## GENERAL ACOUSTIC TERMINOLOGY

### Decibel scale - dB

In practice, when sound intensity or sound pressure is measured, a logarithmic scale is used in which the unit is the 'decibel', dB. This is derived from the human auditory system, where the dynamic range of human hearing is so large, in the order of  $10^{13}$  units, that only a logarithmic scale is the sensible solution for displaying such a range.

### Decibel scale, 'A' weighted - dB(A)

The human ear is less sensitive at frequency extremes, below 125Hz and above 16Khz. A sound level meter models the ears variable sensitivity to sound at different frequencies. This is achieved by building a filter into the Sound Level Meter with a similar frequency response to that of the ear, an A-weighted filter where the unit is dB(A).

### $L_{eq}$

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level  $L_{eq}$ . The  $L_{eq}$  is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

### $L_{10}$

This is the level exceeded for no more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise.

### $L_{90}$

This is the level exceeded for no more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

### $L_{max}$

This is the maximum sound pressure level that has been measured over a period.

### Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 11 such octave bands whose centre frequencies are defined in accordance with international standards. These centre frequencies are: 16, 31.5, 63, 125, 250, 500, 1000, 2000, 4000, 8000 and 16000 Hertz.

Environmental noise terms are defined in BS7445, *Description and Measurement of Environmental Noise*.

## APPLIED ACOUSTIC TERMINOLOGY

### Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than a single source and 4 sources produce a 6dB higher sound level.

### Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

### Subjective impression of noise

Hearing perception is highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a guide to explain increases or decreases in sound levels for many scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud

### Transmission path(s)

The transmission path is the path the sound takes from the source to the receiver. Where multiple paths exist in parallel, the reduction in each path should be calculated and summed at the receiving point. Outdoor barriers can block transmission paths, for example traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and construction.

### Ground-borne vibration

In addition to airborne noise levels caused by transportation, construction, and industrial sources there is also the generation of ground-borne vibration to consider. This can lead to structure-borne noise, perceptible vibration, or in rare cases, building damage.

### Sound insulation - Absorption within porous materials

Upon encountering a porous material, sound energy is absorbed. Porous materials which are intended to absorb sound are known as absorbents, and usually absorb 50 to 90% of the energy and are frequency dependent. Some are designed to absorb low frequencies, some for high frequencies and more exotic designs being able to absorb very wide ranges of frequencies. The energy is converted into both mechanical movement and heat within the material; both the stiffness and mass of panels affect the sound insulation performance.

## APPENDIX B

### 40-50 Tottenham Street

#### PLANT NOISE EMISSIONS CALCULATIONS

Source: Rooftop Plant 40-50 Tottenham Street Receiver: Top Floor Window 25 Cleveland Street	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Condensers at south of plant compound (Sound Pressure Level @2.5m)	68	67	65	62	58	52	47	40	59
Minimum attenuation provided by distance (50m), dB	-26	-26	-26	-26	-26	-26	-26	-26	
Total Specific Level of southern condensers at Receiver	42	41	39	36	32	26	21	14	38
Condensers serving AHU (Sound Pressure Level @1m)	78	72	72	69	64	57	53	43	66
Minimum attenuation provided by distance (45m), dB	-33	-33	-33	-33	-33	-33	-33	-33	
Total Specific Level of southern condensers at Receiver	45	39	39	36	31	24	20	10	37
AHU Supply Casing Breakout (Sound Pressure Level @1m)	69	67	60	58	53	52	50	38	57
Minimum attenuation provided by distance (45m), dB	-33	-33	-33	-33	-33	-33	-33	-33	
Total Specific Level of southern condensers at Receiver	36	34	27	25	20	19	17	5	27
AHU Extract Casing Breakout (Sound Pressure Level @1m)	69	67	60	58	53	52	50	38	57
Minimum attenuation provided by distance (40m), dB	-32	-32	-32	-32	-32	-32	-32	-32	
Total Specific Level of southern condensers at Receiver	37	35	28	26	21	20	18	6	29
AHU Extract termination point 1 (Sound Pressure Level @1m)	72	63	59	62	59	54	49	42	60
Minimum attenuation provided by distance (40m), dB	-32	-32	-32	-32	-32	-32	-32	-32	
Total Specific Level of southern condensers at Receiver	40	31	27	30	27	22	17	10	31
AHU Extract termination point 2 (Sound Pressure Level @1m)	72	63	59	62	59	54	49	42	60
Minimum attenuation provided by distance (50m), dB	-34	-34	-34	-34	-34	-34	-34	-34	
Total Specific Level of southern condensers at Receiver	38	29	25	28	25	20	15	8	29
AHU Supply termination point 1&2 (Sound Pressure Level @1m)	68	66	61	59	52	44	41	31	54
Correction due to number of units (2), dB	3	3	3	3	3	3	3	3	
Minimum attenuation provided by distance (45m), dB	-33	-33	-33	-33	-33	-33	-33	-33	
Total Specific Level of southern condensers at Receiver	38	36	31	29	22	14	11	1	29
<b>Extraction Fan - Noise Emissions from Duct Termination Point</b>									
Toilet Extract Fan (Sound Power Level)	85	84	81	78	71	69	66	61	79
Correction due to duct end reflection, dB	-4	-1	0	0	0	0	0	0	
Conversion to SPL@1m	-11	-11	-11	-11	-11	-11	-11	-11	
Correction due to surface reflections (1), dB	3	3	3	3	3	3	3	3	
Minimum attenuation provided by distance (55m), dB	-35	-35	-35	-35	-35	-35	-35	-35	
Minimum attenuation required from proposed silencer, dB	-5	-7	-15	-30	-28	-20	-15	-11	
<b>Total Noise Emissions from Extraction Fan Duct Termination Point, dB</b>	33	33	23	5	0	6	8	7	20
<b>Extraction Fan - Noise Breakout from Fan Casing Breakout</b>									
Toilet Extract Fan Case Breakout (Sound Power Level)	77	78	70	54	40	38	44	35	65
Conversion to SPL@1m	-11	-11	-11	-11	-11	-11	-11	-11	
Correction due to surface reflections (1), dB	3	3	3	3	3	3	3	3	
Minimum attenuation provided by distance (55m), dB	-35	-35	-35	-35	-35	-35	-35	-35	
<b>Total Noise Emissions from Fan Casing Breakout, dB</b>	34	35	27	11	-3	-5	1	-8	22
<b>Total Specific Level of all Plant Unit Installations at Receiver</b>	49	46	43	40	36	30	26	18	42
<b>Total Rating Noise Level of all Plant Unit Installations at Receiver</b>	49	46	43	40	36	30	26	18	42

Design Criterion

42



Source: Rooftop Plant 40-50 Tottenham Street Receiver: Top Floor Window 38 Tottenham Street	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Condensers at south of plant compound (Sound Pressure Level @2.5m)	68	67	65	62	58	52	47	40	59
Minimum attenuation provided by distance (27m), dB	-21	-21	-21	-21	-21	-21	-21	-21	
Minimum attenuation provided by the building envelope, dB	-9	-11	-13	-16	-19	-22	-25	-28	
Total Specific Level of southern condensers at Receiver	38	35	31	25	18	9	1	-9	27
Condensers serving AHU (Sound Pressure Level @1m)	78	72	72	69	64	57	53	43	66
Minimum attenuation provided by distance (33m), dB	-30	-30	-30	-30	-30	-30	-30	-30	
Minimum attenuation provided by the building envelope, dB	-9	-11	-13	-16	-19	-22	-25	-28	
Total Specific Level of southern condensers at Receiver	39	31	28	22	15	5	-2	-15	24
AHU Supply Casing Breakout (Sound Pressure Level @1m)	69	67	60	58	53	52	50	38	57
Minimum attenuation provided by distance (30m), dB	-30	-30	-30	-30	-30	-30	-30	-30	
Minimum attenuation provided by the building envelope, dB	-9	-11	-13	-16	-19	-22	-25	-28	
Total Specific Level of southern condensers at Receiver	31	26	17	12	4	0	-5	-19	15
AHU Extract Casing Breakout (Sound Pressure Level @1m)	69	67	60	58	53	52	50	38	57
Minimum attenuation provided by distance (27m), dB	-29	-29	-29	-29	-29	-29	-29	-29	
Total Specific Level of southern condensers at Receiver	40	38	31	29	24	23	21	9	32
AHU Extract termination point 1 (Sound Pressure Level @1m)	72	63	59	62	59	54	49	42	60
Minimum attenuation provided by distance (27m), dB	-29	-29	-29	-29	-29	-29	-29	-29	
Total Specific Level of southern condensers at Receiver	43	34	30	33	30	25	20	13	35
AHU Extract termination point 2 (Sound Pressure Level @1m)	72	63	59	62	59	54	49	42	60
Minimum attenuation provided by distance (27m), dB	-29	-29	-29	-29	-29	-29	-29	-29	
Total Specific Level of southern condensers at Receiver	43	34	30	33	30	25	20	13	35
AHU Supply termination point 1&2 (Sound Pressure Level @1m)	68	66	61	59	52	44	41	31	54
Correction due to number of units (2), dB	3	3	3	3	3	3	3	3	
Minimum attenuation provided by distance (29m), dB	-29	-29	-29	-29	-29	-29	-29	-29	
Minimum attenuation provided by the building envelope, dB	-9	-11	-13	-16	-19	-22	-25	-28	
Total Specific Level of southern condensers at Receiver	33	29	21	17	7	-4	-10	-23	18
<b>Extraction Fan - Noise Emissions from Duct Termination Point</b>									
Toilet Extract Fan (Sound Power Level)	85	84	81	78	71	69	66	61	79
Correction due to duct end reflection, dB	-4	-1	0	0	0	0	0	0	
Conversion to SPL@1m	-11	-11	-11	-11	-11	-11	-11	-11	
Correction due to surface reflections (1), dB	3	3	3	3	3	3	3	3	
Minimum attenuation provided by distance (19m), dB	-26	-26	-26	-26	-26	-26	-26	-26	
Minimum attenuation required from proposed silencer, dB	-5	-7	-15	-30	-28	-20	-15	-11	
Minimum attenuation provided by the building envelope, dB	-4	-6	-9	-11	-14	-17	-20	-23	
<b>Total Noise Emissions from Extraction Fan Duct Termination Point, dB</b>	38	36	24	3	-5	-2	-3	-7	22
<b>Extraction Fan - Noise Breakout from Fan Casing Breakout</b>									
Toilet Extract Fan Case Breakout (Sound Power Level)	77	78	70	54	40	38	44	35	65
Conversion to SPL@1m	-11	-11	-11	-11	-11	-11	-11	-11	
Correction due to surface reflections (1), dB	3	3	3	3	3	3	3	3	
Minimum attenuation provided by distance (19m), dB	-26	-26	-26	-26	-26	-26	-26	-26	
Minimum attenuation provided by the building envelope, dB	-4	-6	-9	-11	-14	-17	-20	-23	
<b>Total Noise Emissions from Fan Casing Breakout, dB</b>	39	38	28	9	-8	-13	-10	-22	24
<b>Total Specific Level of all Plant Unit Installations at Receiver</b>	49	45	38	38	34	30	26	17	39
<b>Total Rating Noise Level of all Plant Unit Installations at Receiver</b>	49	45	38	38	34	30	26	17	39

Design Criterion	42
------------------	----

## ANTI-VIBRATION MOUNTING SPECIFICATION REFERENCE DOCUMENT

### 1.0 General

- 1.1 All mountings shall provide the static deflection, under the equipment weight, shown in the schedules. Mounting selection should allow for any eccentric load distribution or torque reaction, so that the design deflection is achieved on all mountings under the equipment, under operating conditions.
- 1.2 It is the supplier's responsibility to ensure that all mountings offered are suitable for the loads, operating and environmental conditions which will prevail. Particular attention should be paid to mountings which will be exposed to atmospheric conditions to prevent corrosion.
- 1.3 All mountings shall be colour coded, or otherwise marked, to indicate their load capacity, to facilitate identification during installation.

Where use of resilient supports allows omission of pipe flexible connections for vibration/noise isolation, it shall be the Mechanical Service Consultant's or Contractor's responsibility to decide whether such devices are required to compensate for misalignment or thermal strain.

### 2.1 Type A Mounting (Caged Spring Type)

- 2.1.1 Each mounting shall consist of cast or fabricated telescopic top and bottom housings enclosing one or more helical steel springs as the principle isolation elements, and shall incorporate a built-in levelling device. The housing should be designed to permit visual inspection of the springs after installation, i.e. the spring must not be totally enclosed.
- 2.1.2 The springs shall have an outside diameter of not less than 75% of the operating height, and be selected to have at least 50% overload capacity before becoming coil-bound.
- 2.1.3 The bottom plate of each mounting shall have bonded to it a rubber/neoprene pad designed to attenuate any high frequency energy transmitted by the springs.
- 2.1.4 Mountings incorporating snubbers or restraining devices shall be designed so that the snubbing, damping or restraining mechanism is capable of being adjusted to have no significant effect during the normal running of the isolated machine.
- 2.1.5 All nuts, bolts or other elements used for adjustment of a mounting shall incorporate locking mechanisms to prevent the isolator going out of adjustment as a result of vibration or accidental or unauthorised tampering.

### 2.2 Type B Mounting (Open Spring Type)

- 2.2.1 Each mounting shall consist of one or more helical steel springs as the principal isolation elements, and shall incorporate a built-in levelling device.
- 2.2.2 The springs shall be fixed or otherwise securely located to cast or fabricated top and bottom plates, shall have an outside diameter of not less than 75% of the operating height, and shall be selected to have at least 50% overload capacity before becoming coil-bound.
- 2.2.3 The bottom plate shall have bonded to it a rubber/ neoprene pad designed to attenuate any high frequency energy transmitted by the springs.

## **2.3 Type C Mounting (Rubber/Neoprene Type)**

Each mounting shall consist of a steel top plate and base plate completely embedded in oil resistant rubber/neoprene. Each mounting shall be capable of being fitted with a levelling device, and should have bolt holes in the base plate and a threaded metal insert in the top plate so that they can be bolted to the floor and equipment where required.

## **3.0 Plant Bases**

### **3.1 Type A Bases (A.V. Rails)**

An A.V. Rail shall comprise a steel beam with two or more height-saving brackets. The steel sections must be sufficiently rigid to prevent undue strain in the equipment and if necessary should be checked by the Structural Engineer.

### **3.2 Type B Bases (Steel Plant Bases)**

Steel plant bases shall comprise an all-welded steel framework of sufficient rigidity to provide adequate support for the equipment, and fitted with isolator height saving brackets. The frame depth shall be approximately 1/10 of the longest dimension of the equipment with a minimum of 150 mm. This form of base may be used as a composite A.V. rail system.

### **3.3 Type C Bases (Concrete Inertia Base: for use with steel springs)**

These shall consist of an all-welded steel pouring frame-work with height saving brackets, and a frame depth of approximately 1/12 of the longest dimension of the equipment, with a minimum of 100 mm. The bottom of the pouring frame should be blanked off, and concrete (2300 kg/m<sup>3</sup>) poured in over steel reinforcing rods positioned 35 mm above the bottom. The inertia base should be sufficiently large to provide support for all parts of the equipment, including any components which over-hang the equipment base, such as suction and discharge elbows on centrifugal pumps.