





 THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL GENERAL ARRANGEMENT DRAWINGS, PROJECT DETAILS AND SPECIFICATIONS. 2. UNLESS NOTED OTHERWISE, ALL DIMENSIONS ARE TO STRUCTURAL FACES AND/OR PARTITION STUDS.

8. ELECTRIC AND M&E WORK TO BE CARRIED OUT BY QUALIFIED AND REGISTERED SPECIALIST. 9. ALL DRAINAGE RUNS TO BE ABOVE FLOOR UNLESS STATED OTHERWISE

10. KITCHEN LAYOUT TO SPECIALIST'S DESIGN AND DETAILS

INDICATES EXTRACT LOCATION

5. LEGEND
////// NEW FACING BRICKWORK TO MATCH WITH THE EXISTING. 7.3 N/SQ. IMI LOADBEARING AIRCRETE BLOCK (450 - 800 Kg/M³) TO EXTERNAL CAVITY WALL TO CLIENTS SPECIFICATION. BLOCK STRENGTH TO BE CONFIRMED AND DETAILED BY THE STRUCTURAL ENGINEER

NEW NON-LOADBEARING PARTITION,
70MM TIMBER STUDS WITH 12.5MM SOUNDBLOC RAPID BOARD ON EACH SIDE. 12.5MM PLY BOARD TO
BE USED TO SUPPORT MAIN WALL IN BEDROOMS AND ALL SIDES OF BATHROOM AND KITCHEN FOR
APPLIANCES FIXTURES. PARTITION TO ACHIEVE MINIMUM 4005 SOUND REDUCTION. MR GRADE
BOARD TO BE USED IN WET AREAS. PLEASE CONFIRM FROM CLIENT IF TIMBER STUD TO BE REPLACED
WITH GYPFRAME C: STUDS.
30MM SOUND QUILT INSULATION TO BE FILLED AS INDICATED ON FLOOR PLANS

WALL FOR ATTIC ROOM, EXACT SIZE OF TIMBER TO BE CONFIRMED BY FINGINFED DENOTES SPAN OF FLOOR OVER (TYPE STATED)

CRANKED STEEL BEAM (CSB) TR

6. — DENOTES STRUCTURAL STEEL BEAM/TIMBER
TRIMMER OVER. ALL STEEL BEAMS TO HAVE MINIMUM 1 HOUR
FIRE PROTECTION.

(38) STEEL BEAM

SITE PLAN PLAN Sheet 1 For Planning Approval

Drawing Title
SHOP

41 South End Road London NW3 2PY

SCUK22 0007 3



11. MECHANICAL VENTILATION
ALL EXTRACT DUCTS TO RUN BE WITHIN FLOORS AND ROOF VOID UNLESS STATED OTHERWISE.