

Application ref: 2022/3608/P
Contact: Edward Hodgson
Tel: 020 7974 8186
Email: Edward.Hodgson@camden.gov.uk
Date: 9 February 2023

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Rolfe Judd Planning
Old Church Court
Claylands Road
Oval
London
SW8 1NZ

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
27 Goodge Street
London
W1T 2LD

Proposal: Installation of 6 new air source heat pumps on the rear first floor

Drawing Nos: Site Location Plan C-001-P2, C-100-P2, C-101-P2, C-102-P2, C-200-P3, C-201-P3, C-202-P3, Overheating Analysis R2 (prepared by Quinn Ross Energy dated 27/01/2023), Environmental Noise Survey and Plant Noise Assessment Report (prepared by Hann Tucker Associates dated 19/08/2022), Acoustic Enclosure Details (prepared by environ group dated 09/09/2022).

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans

Site Location Plan C-001-P2, C-100-P2, C-101-P2, C-102-P2, C-200-P3, C-201-P3, C-202-P3, Overheating Analysis R2 (prepared by Quinn Ross Energy dated 27/01/2023), Environmental Noise Survey and Plant Noise Assessment Report (prepared by Hann Tucker Associates dated 19/08/2022), Acoustic Enclosure Details (prepared by environ group dated 09/09/2022)

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 The external noise level emitted from plant, machinery or equipment at the development with specified noise mitigation hereby approved shall be lower than the typical existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the surrounding premises is not adversely affected by noise from equipment in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 4 Prior to use, machinery, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation

will be granted until the Construction Management Plan is approved by the Council.

- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at www.camden.gov.uk) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2021.

You can find advice about your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

Yours faithfully



Daniel Pope
Chief Planning Officer