




Subject:

CAAC Consultation Comments Received

Camden Council



Here's what **Someone** entered into the form:

Enter Pin



Application ref.

2023/0660/L

Site Address

72 Albert Street London Camden NW1 7NR

Development Description

This application seeks permission to replace a number of the existing sash windows which appear to be either in bad state or non original. The new windows will match the original ones.

Planning officer

Rose Todd

Advisory committee

Camden Town

Advisory committee

Please send your comments by:

2023-03-14T00:00:00.000

Please choose one

Comment

Do you have any comments or consider that the proposal is harmful to or does not preserve the character and appearance of the conservation area?

We have some concerns about the proposed replacements of the 2nd floor windows which appear to be original sashes without horns (and not more modern replacements). Original sashes can always be repaired with new timber to match the existing scarfed in, and we would strongly encourage the applicant to take this route rather than wholesale replacement. It is more sustainable and will result in maximum retention of historic fabric.

Do you want to attach any files?

Attach files

Content is temporarily unavailable.

To receive a confirmation email, enter your address below:

