

Application ref: 2022/3237/P  
Contact: Cameron Banks-Murray  
Tel: 020 7974 2078  
Email: Cameron.Banks-Murray@camden.gov.uk  
Date: 3 February 2023

**Development Management**  
Regeneration and Planning  
London Borough of Camden  
Town Hall  
Judd Street  
London  
WC1H 9JE

Phone: 020 7974 4444

[planning@camden.gov.uk](mailto:planning@camden.gov.uk)

[www.camden.gov.uk/planning](http://www.camden.gov.uk/planning)

Sufair Ltd  
36 Wolsey Crescent  
New Addington  
Croydon  
CR0 0PE

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Full Planning Permission Granted**

Address:

**86 Plender Street  
London  
Camden  
NW1 0JN**

Proposal:

Installation of an extractor fan and flue on the rear elevation in association with the existing restaurant (Class E use).

Drawing Nos: 1340\_02\_01 Proposed Plans; 1340\_00\_01 Existing Plans; Noise Impact Assessment; Plant Extraction Report

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans: 1340\_02\_01 Proposed Plans; 1340\_00\_01 Existing

Plans.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 The external flue hereby approved will be painted matt black and shall be maintained this colour.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 Before the use commences, the extract ventilating system shall be provided with sound attenuation and anti-vibration measures in accordance with the scheme approved in writing by the local planning authority. All such measures shall thereafter be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1, A4, and D1 of the London Borough of Camden Local Plan 2017.

- 5 The external noise level emitted from the installation at the development with any specified noise mitigation hereby approved shall be lower than the typical existing background noise level by at least 10dBA, by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive receptor, with the installation operating at maximum capacity. A post installation noise assessment shall be carried to confirm compliance with the noise criteria and additional steps to mitigate noise shall be taken, as necessary. Approved details shall be implemented prior to occupation of the development and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from mechanical installations/ equipment in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 6 Prior to use, machinery, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To ensure that the amenity of occupiers of the development site and surrounding premises is not adversely affected by vibration in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 7 The installation, operation, and maintenance of the odour abatement equipment and extract system, including the height of the extract duct and vertical discharge outlet should be in accordance with the 'EMAQ+Control of Odour and Noise from Commercial Kitchen Exhaust Systems. Approved details shall be implemented prior to the commencement of the use and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from mechanical installations/ equipment in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 3 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at [www.camden.gov.uk](http://www.camden.gov.uk)) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2021.

You can find advice about your rights of appeal at:

[https://www.gov.uk/appeal-planning-decision.](https://www.gov.uk/appeal-planning-decision)

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned in the upper left corner of the page.

Daniel Pope  
Chief Planning Officer